



CITY OF ROCKVILLE  
PURCHASING DIVISION  
111 MARYLAND AVENUE  
ROCKVILLE, MARYLAND  
PHONE: (240) 314-8430

## ADDENDUM NO. 2

### INVITATION FOR BID 33-12 SANITARY SEWER REHABILITATION VARIOUS LOCATIONS

**DATE:** November 27, 2012

---

Contractors submitting proposals for the above named project shall take note of the following changes, additions, deletions and clarifications in the Bid Documents, which shall become a part of and have precedence over anything contrarily shown or described in the Bid Documents and all such shall be taken into consideration and be included in the Contractor's Bid Proposal.

#### QUESTIONS AND RESPONSES

1. I would like to know if the following contract has a required MBE subcontracting requirement and if so what percentage would that requirement be.

*Response: The Contractor is advised that solicitation of DBEs shall occur as part of the bid proposal preparation to ensure the necessary quotes are reflected in the submitted bid proposal. The Contractor and all subcontractors are required to make a good-faith effort to award a fair share of work to Disadvantaged Business Enterprises (DBEs).*

2. Will you be requiring a LMK Shorty style lateral seal for each lateral connection on this contract or are you only expecting the lateral to be re-instated?

*Response: The laterals shall only be reinstated, no lateral rehabilitation is proposed for this contract.*

3. Does the city have depths for the manholes?

*Response: No, the City does not have depth information for each manhole; however, design sheets and as-builts, if available, will be made available to the selected contractor.*

4. Are there any CCTV reports available?

*Response: The City has CCTV video inspections of all of the sewers proposed in this contract, however CCTV reports have not been generated and are therefore unavailable. All sewers in the contract have at least one PACP-5 defect.*

5. How many services laterals are on these lines that are identified?

*Response: The exact number of service laterals is not known, but the estimated quantity is 400 which is based on an estimate of 8 sewer house connections for every 250 LF of sewer pipe.*

6. Is the specified thickness for the liners the installed thickness?

*Response: The specified thickness for the liners shall be the installed thickness.*

7. Where does the cutting of service laterals & protruding taps get paid for in the defined 6" & 8" CIPP lining work? Is it in the CIPP lining items or the contingent bid items?

*Response: Cutting of service laterals is paid through contingent item No. 4 and trimming protruding taps is paid through contingent item No. 6. Neither is part of Items No. 1 and 2.*

8. How many laterals will need to be re-instated on the 6" main that is to be lined? It is very difficult to reinstate laterals on any line under 8" in diameter due to the size of the cutter.

*Response: The exact amount of sewer house connections is unknown on the 6" sewer main, however it can be assumed that there are 8 service connections per 250 LF of sanitary sewer. Therefore, assume that there are approximately 80 sewer house connections on the 6" mains.*

9. What is the minimum thickness for UV Cured liner on the 6" main? The chart in the spec starts at 8".

*Response: The minimum thickness for UV cured liners of 6" mains is equivalent to the 8" minimum thickness.*

10. For the lateral reinstatement, the specification clearly shows the Janssen Process as a means to seal the lateral/mainline interface. Is this expected on all reinstatements? There is no separate line item for this in the bid sheets but the pay items do describe sealing to be part of the reinstatement process. Please clarify.

*Response: No lateral-mainline rehabilitation interface is required on this project. The only thing required is the reinstatement of sewer lateral connections.*

All other terms and conditions remain the same.

**ISSUED BY:**

**Eileen Morris**  
Purchasing Manager

**ACKNOWLEDGE RECEIPT OF ADDENDUM NO 2 BY EITHER SIGNING BELOW AND RETURNING A COPY OF THE ADDENDUM WITH YOUR BID OR BY ACKNOWLEDGING ON THE BID PROPOSAL FORM.**

**NAME OF FIRM:** \_\_\_\_\_

**AUTHORIZED SIGNATURE:** \_\_\_\_\_